



Product Service

CERTIFICATE

No. U6 13 09 86105 001

Holder of Certificate: **AS LED Lighting GmbH**Seeshaupter Str. 2
82377 Penzberg
GERMANYProduction
Facility(ies):

86094

Certification Mark:



Product:

**Internal lights
stationary**

Model(s):

HCL-050037-xxx-14; HCL-050037-xxx-18
HCL-057057-xxx-24; HCL-057057-xxx-27;
HCL-057057-xxx-33

"xxx" = illuminant chromaticity

640: CRI=65, 4000K; 740: CRI=75, 4000K,
3000K, 830: CRI=85, 3000K, 840: CRI=85,
4000K, 850: CRI=85, 5000K, 756: CRI=75,
5700K, 765: CRI=75, 6500K, 930: CRI=95

Parameters:

Rated voltage:	220 - 240 V~
Rated frequency:	50-60 Hz
Rated power:	-HCL-050037-xxx-14: 114W/700mA (LED) -HCL-050037-xxx-18: 146W/700mA (LED) -HCL-057057-xxx-24: 195W/700mA (LED) -HCL-057057-xxx-27: 220W/700mA (LED) -HCL-057057-xxx-33: 268W/700mA (LED)


Protection class:	I
Degree of protection:	IP54

Tested
according to:EN 60598-1/A11:2009
EN 60598-2-1:1989
EN 60598-2-24:1998
EN 62471:2008
EN 62493:2010

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.: 028-713020347-000

Date, 2013-10-08


(Klaus Ludwig)

Page 1 of 1

